

Massachusetts Water Quality Standards

<http://www.mass.gov/dep/water/laws/regulati.htm#wqual>

- **Class A** (CMR 4:05,3,a)
 - Potable water; not to exceed 20 *E-coli* organisms/100ml

- **Class B** (CMR 4:05,3,b))
 - Suitable for irrigation; not to exceed 126 *E-coli* colonies/100ml

- **Class C** (CMR 4:05,3,c) Standard)
 - Suitable for irrigation of crops used for consumption after cooking, not to exceed 630 *E-coli* colonies/100ml

For detailed information on Massachusetts Water Quality standards visit the website above. All other New England states should check with their state GAP coordinator.

Bob Rondeau, Program Coordinator
Massachusetts Department of Agricultural Resources (MDAR)
Ph # 617-626-1804
robert.rondeau@state.ma.us