



Potential for Solar PV on MA Highway Sound Barriers



College of Natural Sciences
Center for Agriculture, Food,
and the Environment

Eamon Breen and Dwayne Breger

UMassAmherst
Clean Energy Extension

United States Department of Agriculture
National Institute of Food and Agriculture

Introduction

In Massachusetts, solar energy can provide a more sustainable method of energy generation in the urban areas of the future. Noise barriers offer the opportunity to be used in conjunction with solar arrays, referred to as PVNBs (photovoltaic noise barriers). The goals of this project were as follows: create a GIS layer and database detailing each sound barrier in the state and their characteristics (location, surface area, length, height, building material, etc.); identify the potential for these sites to be used as PVNBs, through the National Renewable Energy Laboratory's PVWatts tool, finding energy generation potential for each site and as a whole.

Figure 1: 3D rendering of proposed PVNB along Route 128 in Lexington.




Figure 2: PVNB along the A50 motorway in the Netherlands.

Methods

This project employed the use of GIS software ArcGIS Pro for the creation of a database modelled after MassDOT's 2018 sound barrier inventory. Using ArcGIS, geographic representations of each noise barrier along with data sourced from NREL's PVWatts solar energy calculator was created.

Figure 3: Map of a typical noise barrier, created using ArcGIS Pro.



Results

PVNBs could add 42 MW and 37,000 MWh of electricity to MA's grid

| 30 Degree PVNB | 90 Degree PVNB |
|---|---|
| Aggregate Energy Production (MWh): 23,531.6 | Aggregate Energy Production (MWh): 36,790.2 |
| Aggregate DC System Size (MW): 19.5 | Aggregate DC System Size (MW): 42.4 |
| Mean Energy Production (MWh): 322.3 | Mean Energy Production (MWh): 503.9 |
| Mean DC System Size (MW): 0.3 | Mean DC System Size (MW): 0.6 |

Figure 4: Aggregate and mean potential energy production and DC system size for PVNBs across MA.

19 large sound barriers possess equivalent energy potential to the other 54 sites




Figure 5: Locations of 19 sound barriers that possess roughly half of the potential energy generation for PVNBs across MA (at both 30- and 90-degree tilt angles).

Final database offers a resource to those considering PVNB development and potential.

| ID | City | StateRef | Route | Average_Ht | Length_Feet | Area_Sq_Ft | constn | Primary_material | DDLat | DDLen | energy_30_kwh | energy_90_kwh | azimuth | zfp | dc_size_30 | dc_size_90 | city | facility | fat_90 | |
|----|----------------------------|---------------|-------|------------|-------------|------------|------------------|-------------------|-------|--------|---------------|---------------|---------|--------|------------|------------|------|----------|--------|--|
| 2 | Buxford | 195 @ MA | 195 | 7 | 1,240 | 8,680 | 1975 | Berm | 42.65 | -70.98 | 84269 | 140913 | 154.388 | 01921 | 70.68 | 164.92 | 13.6 | 9.8 | | |
| 3 | Buxford | 195 @ Upt 195 | 195 | 10 | 1,050 | 16,500 | 1975 | Wood | 42.65 | -70.98 | 197410 | 222765 | 176.298 | 01921 | 188.1 | 313.5 | 12 | 8.1 | | |
| 4 | Buxford | 195 @ Rpt 195 | 195 | 10 | 3,300 | 33,000 | 1975 | Wood | 42.68 | -70.98 | 383170 | 428839 | 8.7592 | 01921 | 376.2 | 627 | 11.6 | 7.8 | | |
| 5 | Newbury 195 @ Cst 195 | 195 | 195 | 7 | 850 | 5,950 | 1975 | Precast Concrete | 42.81 | -70.91 | 50849 | 79915 | 181.201 | 01950 | 48.45 | 113.05 | 12 | 8.1 | | |
| 6 | Newbury 195 @ Lst 195 | 195 | 195 | 7 | 1,148 | 8,036 | 1975 | Precast Concrete | 42.83 | -70.92 | 48310 | 104396 | 15.025 | 01950 | 65.44 | 152.88 | 11.9 | 7.8 | | |
| 7 | Newbury 195 @ Sst 195 | 195 | 195 | 7 | 1,650 | 11,550 | 1975 | Precast Concrete | 42.81 | -70.92 | 103889 | 163080 | 178.727 | 01950 | 94.05 | 219.45 | 12.5 | 8.5 | | |
| 8 | Newbury 195 @ Cst 195 | 195 | 195 | 7 | 1,659 | 11,893 | 1975 | Precast Concrete | 42.82 | -70.92 | 116557 | 191202 | 137.153 | 01950 | 96.843 | 225.97 | 13.7 | 9.7 | | |
| 9 | Leominster Rt 2 @ Rst SR 2 | 195 | 195 | 7 | 249 | 1,743 | 1976 | Wood | 42.52 | -71.72 | 18834 | 31595 | 300.149 | 01453 | 14.193 | 33.12 | 15.1 | 10.9 | | |
| 10 | Leominster Rt 2 @ Mc SR 2 | 195 | 195 | 7 | 400 | 2,800 | 1976 | Wood | 42.52 | -71.71 | 30254 | 50668 | 88.553 | 01453 | 22.8 | 58.2 | 15.7 | 10.8 | | |
| 11 | Leominster 190 @ Rt 190 | 190 | 190 | 7 | 2,601 | 18,207 | 1976 | Wood | 42.54 | -71.74 | 185480 | 313797 | 133.612 | 01453 | 148.26 | 345.93 | 14.3 | 10.4 | | |
| 12 | Lancaster 190 @ N 190 | 190 | 190 | 3 | 800 | 2,400 | 1979 | Berm | 42.49 | -71.72 | 51506 | 86277 | 169.939 | 01523 | 45.6 | 45.6 | 12.9 | 9.1 | | |
| 13 | Leominster 190 @ Rt 190 | 190 | 190 | 3 | 2,259 | 4,897 | 1979 | Berm | 42.51 | -71.72 | 141982 | 97942 | 167.686 | 01453 | 321.04 | 321.04 | 12.4 | 8.5 | | |
| 14 | Mansfield 1495 @ H 1495 | 190 | 190 | 10 | 2,659 | 26,990 | 1980 | Berm, Combination | 42 | -71.2 | 404962 | 484713 | 283.183 | 02766 | 307.68 | 512.81 | 15 | 10.8 | | |
| 15 | Norton 1495 @ N 1495 | 190 | 190 | 16 | 2,401 | 38,416 | 1980 | Berm | 41.99 | -71.17 | 508825 | 654488 | 296.741 | 02766 | 410.57 | 729.9 | 14.1 | 10.2 | | |
| 16 | Leominster 190 @ J 190 | 190 | 190 | 7 | 200 | 1,400 | 1980 | Wood | 42.51 | -71.72 | 12859 | 21175 | 343.864 | 01453 | 11.4 | 26.8 | 12.9 | 9.1 | | |
| 17 | Worcester 190 @ W 190 | 190 | 190 | 16 | 800 | 12,800 | 1980 | Metal | 42.3 | -71.8 | 170280 | 218187 | 146.161 | 01606 | 136.8 | 248.2 | 14.2 | 10.2 | | |
| 18 | Raynham 1495 @ E 1495 | 190 | 190 | 10 | 2,506 | 25,060 | 1981 | Berm, Combination | 41.96 | -71.07 | 378582 | 450398 | 271.874 | 02767 | 285.68 | 476.14 | 15.1 | 10.8 | | |
| 19 | West Boy 190 @ Pt 190 | 190 | 190 | 13 | 964 | 12,532 | 1981 | Berm, Combination | 42.34 | -71.8 | 158988 | 212488 | 129.202 | 01583 | 128.21 | 238.11 | 14.2 | 10.2 | | |
| 20 | Mansfield Rt 149 @ SR 149 | 190 | 190 | 10 | 1,206 | 12,060 | 1983 | Berm, Combination | 42.01 | -71.22 | 165220 | 194199 | 162.474 | 02048 | 144.66 | 241.11 | 11 | 9.2 | | |
| 21 | Peachbody 195 @ Cst 195 | 195 | 195 | 10 | 492 | 4,920 | 1987 | Precast Concrete | 42.54 | -70.98 | 37596 | 59092 | 18.4349 | 01960 | 28.04 | 93.48 | 11.2 | 7.2 | | |
| 22 | Peachbody Rt 129 @ Rt 129 | 195 | 195 | 10 | 787 | 7,870 | 1987 | Precast Concrete | 42.52 | -70.97 | 60190 | 144373 | 256.8 | 01960 | 44.859 | 149.53 | 15.3 | 11 | | |
| 23 | Natick 195 @ Hst 195 | 195 | 195 | 14 | 2,070 | 29,080 | 1994 | Wood | 42.21 | -71.36 | 868691 | 130493 | 66.532 | 01760 | 375.31 | 550.62 | 15.3 | 11 | | |
| 24 | Somerville 193 @ Bar 193 | 190 | 190 | 10 | 2,417 | 24,170 | 1995 | Precast Concrete | 42.4 | -71.09 | 189875 | 405430 | 126.939 | 02145 | 137.76 | 459.23 | 14.1 | 10.1 | | |
| 25 | Somerville 193 @ Car 193 | 190 | 190 | 11 | 1,197 | 13,167 | 1996 | Precast Concrete | 42.38 | -71.08 | 77205 | 170665 | 188.213 | 02139 | 75.05 | 250.17 | 11.7 | 7.8 | | |
| 26 | Quincy 195 @ Car 195 | 195 | 195 | 12 | 1,000 | 12,000 | 2001 | Precast Concrete | 42.52 | -71.09 | 145568 | 209231 | 111.889 | 02189 | 114 | 238 | 14.6 | 10.5 | | |
| 27 | Wakefield 195 @ Sst 195 | 195 | 195 | 25 | 5,000 | 126,105 | 2001 | Precast Concrete | 42.52 | -71.05 | 1667531 | 2473265 | 96.664 | 01056 | 1254 | 2585.98 | 15.2 | 10.9 | | |
| 28 | Milton 193 @ Gr 193 | 195 | 195 | 15 | 2,300 | 34,500 | 2001 | Precast Concrete | 42.27 | -71.05 | 461828 | 540474 | 154.504 | 02186 | 393.3 | 655.5 | 13.4 | 9.4 | | |
| 29 | Milton 193 @ Spt 193 | 195 | 195 | 14 | 2,200 | 31,500 | 2002 | Precast Concrete | 42.26 | -71.04 | 467667 | 515914 | 147.475 | 02186 | 384.75 | 598.5 | 13.9 | 9.8 | | |
| 30 | Milton, Ct 193 @ Spt 193 | 195 | 195 | 12 | 1,200 | 14,400 | 2002 | Precast Concrete | 42.25 | -71.04 | 155728 | 215914 | 155.002 | 01609 | 136.8 | 271.6 | 11 | 9 | | |
| 31 | North Car 44 @ Bt US 44 | 195 | 195 | 16 | 2,220 | 35,660 | 2002 | Precast Concrete | 41.94 | -70.78 | 512767 | 627974 | 241.317 | 02330 | 384.04 | 677.92 | 14.9 | 10.6 | | |
| 32 | Plymouth Rt 3 @ Lr US 3 | 195 | 195 | 17 | 800 | 13,600 | 2002 | Precast Concrete | 41.97 | -70.7 | 174977 | 248923 | 111.775 | 02363 | 136.8 | 258.4 | 14.6 | 10.4 | | |
| 33 | Ware 195 @ Wst 195 | 195 | 195 | 19 | 2,025 | 30,380 | 2003 | Wood | 42.3 | -71.46 | 461180 | 702294 | 66.347 | 01791 | 345.42 | 729.22 | 15.2 | 11 | | |
| 34 | Newton 190 @ Bst 190 | 195 | 195 | 16 | 1,531 | 23,730 | 2003 | Wood | 42.35 | -71.2 | 384183 | 440013 | 257.643 | 02458 | 270.53 | 450.87 | 15.4 | 11.1 | | |
| 35 | Chelmsfo Rt 3 @ Mc US 3 | 195 | 195 | 15 | 1986 | 29,440 | 2004 | Precast Concrete | 42.6 | -71.32 | 413223 | 499081 | 126.834 | 01824 | 324.22 | 540.36 | 14.5 | 10.5 | | |
| 36 | Chelmsfo Rt 3 @ C US 3 | 195 | 195 | 20 | 1200 | 24,000 | 2004 | Precast Concrete | 42.61 | -71.33 | 221953 | 393142 | 10.8634 | 01824 | 205.2 | 456 | 12.3 | 8.3 | | |
| 37 | Chelmsfo Rt 3 @ Lst US 3 | 195 | 195 | 1901 | 35,300 | 2004 | Precast Concrete | 42.63 | -71.4 | 464847 | 638424 | 290.243 | 01863 | 807.97 | 676.7 | 15 | 10.9 | | | |

Figure 6: Final database – cells in green provide added data on solar potentials to original MassDOT sound barrier inventory.

Future Research

Due to a lack of installed PVNBs to examine, further research overseas and in the US as PVNBs develop is required. Furthermore, as solar technology continues to progress, the efficacy of PVNBs and alterations to their design should be considered in order to facilitate more momentum in the solar energy sector. More research is needed to better understand the full economic implications of the proposed PVNBs discussed for MA, as economic impact was greater than the scope of this report. Finally, although safety for PVNBs has been examined in other reports, pilot programs like that in Lexington should be used to best understand the potential safety hazards regarding glare and driver distraction.

Acknowledgements

I would like to thank UMass Amherst's CAFE Summer Scholars Program for their support in this research. Without their funding and guidance throughout this period, none of this would have been possible. I would also like to thank Dr. Dwayne Breger from UMass Amherst's Clean Energy Extension, for his exhaustive help and instruction during the research, writing, and production of the report and poster.